



## NOTES:

1. Marker Posts shall be used in unimproved easements and Rights of Way to locate manholes, water valves, flushing inlets, blowoffs, electrolysis stations, and other facilities as required by the City Engineer.
2. Posts shall be 4" x 4" x 6'-0" construction heart redwood S4S, and painted with two(2) coats of outside white paint.
3. Legend to be labeled on posts in 3" black letters are as follows:
  - a. On sanitary sewers: C. of M.
  - b. On storm sewers: C. of M.
  - c. On water lines: On side facing valve, show size of valve  
On opposite side, show C. of M.
  - d. On electrolysis stations: T.S. on test stations  
A.S. on anode stations
4. Portion of post to be set in concrete shall be treated to prevent rotting.
5. Only one marker post shall be installed per electrolysis station.

REV	DATE	APPROVED	DESIGN
			DRAWN
			CHECKED
			APPROVED BY
			<i>David M. Kelly</i>
			CITY ENGINEER
			DATE <i>10/21/76</i>

CITY OF MILPITAS

PUBLIC WORKS DEPARTMENT  
ENGINEERING DIVISION  
STANDARD DRAWING

## MARKER POSTS IN EASEMENTS

NO. 204

ADOPTED  
C# 2809  
DATE 9/21/76  
SHEET 1 OF 1